

Supplement to DVRM Firmware V3.00

ATSC

- Messages with "...SI..." changed to "...PSI...", "...PSIP..." or "...PSI/PSIP...".
- In the absence of MGT, TVCT and CVCT, a PSIP REPEAT VCT UPPER DISTANCE (PSIP:R:VCT UPP DIST, 729) report entry is generated.
- The limit for the RRT parameter can be deactivated and activated. This disables and enables the monitoring of the RRT distance. The RRTR parameter has been added to the CONFigure:MONitoring:LIMit remote control command.

New remote control command:

CONFigure:MONitoring:LIMit:RRTR[?] ON | OFF

- Default limit for PAT now 100 ms and for PMT now 400 ms. (according to ATSC Doc. A/53B of 7 Aug. 2001)
- Default limit for PCR now 100 ms.
- The PARADIGM parameter is switched off with RECALL PRESET.
- The monitoring of the upper limit of the EIT distance now also includes EIT1 to EIT3. The following report entries are generated:

PSIP REPEAT EIT1 UPPER DISTANCE (PSIP:R:EIT1 UPP DIST, 726)

PSIP REPEAT EIT2 UPPER DISTANCE (PSIP:R:EIT2 UPP DIST, 727)

PSIP REPEAT EIT3 UPPER DISTANCE (PSIP:R:EIT3 UPP DIST, 728)

- The SYSTem:STANdard:USCable ON command allows the stream type 0x80 to be activated as a video stream.

New remote control command:

SYSTem:STANdard:USCable[?] ON | OFF