

Manufacturer	Wavetek-Datron	Calibration date	October 02 2021
Model Number	4920M	Ambient Temperature	21.70 °C
Serial	WSTD	Relative Humidity	38.23 %
ID Number	Primary	Pressure	1017.39
Notes	DB-UHF / N adapted cable	Test type	Automated verification

This note is test dummy text block for further use. It allow to include user information for further reference

Reference standard	Mfg	Model	Options	Serial / Unc	CEID	Calibration date	Due date
MFC	Fluke	5720A	03/HLK	E2E6	XC01	07/11/2021	10/11/2021
Amplifier	Fluke	5725A		5930005	XB01	07/11/2021	10/11/2021
Divider	Fluke	752A	4295200		XR01	07/11/2021	07/12/2021

Total uncertainty of each calibration point calculated with RSS

$$U_{95\%} = \sqrt{U_{SRC}^2 + U_{DUT}^2} * 2$$

MFC last calibrated	83.0 days ago	MFC since DCV ZERO	2.0 days ago
MFC since WBFLAT	266.0 days ago	MFC since WBGAIN	266.0 days ago
MFC Confidence level	24h 95% REL	MFC Calibrate date	2021-07-11 00:00:00
MFC Calibrate date Zero	2021-09-30 00:00:00	Calibrate date WB Flatness	2021-10-09 00:00:00
Calibrate date WB Gain	2021-10-09 00:00:00	CAL CONST 6.5V reference voltage	6.95747285407
CAL CONST 13V reference voltage	13.8552886589	CAL CONST 22V range positive zero	398.17892
CAL CONST 22V range negative zero	398.17841	CAL CONST DAC Linearity	0.0
CAL CONST 10KOHM true output resistance	9999.79344207	CAL CONST 10KOHM standard resistance	9998.74319091
CAL CONST, Zero calibration temperature	24.0	CAL CONST, All calibration temp	24.0
Meter Info	Wavetek-Datron,4920M, 29336,400935-01.01	Line frequency	60 Hz
Next calibration date	M: D: Y:	Test date	October 02 2021 05:53
DUT Internal TEMP?	NONE	Calibration interval	365.0
PROG?	"ACV 10,RESL7,FILT100HZ, OFF,INT"	Calibration temp (hardcode)	+24.0 °C

Test procedure : \$Id: w4920m.py | Rev 1671 | 2020/03/04 01:44:44 tin_fpga \$

Source procedure : \$Id: f5720a.py | Rev 1637 | 2020/02/02 04:57:47 tin_fpga \$

VAC Ranges performance test.
 Checks calibration on 0.3V - 1000V ranges
 The following test for the offset voltage specification using MFC source in local sense mode as reference.
 Using uncorrected 24-hour MFC output.

Test Description	Measured Value	F5700A 24h			Ref/measured	W4920 Spec	Test Status
Full range ACV Test	0.1V-1000V	Source Uncertainty	Lower Limit	Upper Limit	Deviation	1y spec	Result
0.1 VAC @ 14.99931 Hz	0.0999957	140.45 ppm	0.099986	0.100014	-43.000 ppm	75.0 ppm	PASS 19.96 %
0.1 VAC @ 19.9991 Hz	0.0999953	140.45 ppm	0.099986	0.100014	-47.000 ppm	75.0 ppm	PASS 21.81 %
0.1 VAC @ 39.9983 Hz	0.0999954	140.45 ppm	0.099986	0.100014	-46.000 ppm	75.0 ppm	PASS 21.35 %
0.1 VAC @ 49.9978 Hz	0.0999951	140.45 ppm	0.099986	0.100014	-49.000 ppm	30.0 ppm	PASS 28.75 %
0.1 VAC @ 99.9956 Hz	0.0999956	140.45 ppm	0.099986	0.100014	-44.000 ppm	30.0 ppm	PASS 25.81 %
0.1 VAC @ 399.982 Hz	0.0999959	140.45 ppm	0.099986	0.100014	-41.000 ppm	30.0 ppm	PASS 24.05 %
0.1 VAC @ 999.955 Hz	0.0999959	140.45 ppm	0.099986	0.100014	-41.000 ppm	30.0 ppm	PASS 24.05 %
0.1 VAC @ 1.99991 kHz	0.0999965	140.45 ppm	0.099986	0.100014	-35.000 ppm	30.0 ppm	PASS 20.53 %
0.1 VAC @ 2.99987 kHz	0.0999964	140.45 ppm	0.099986	0.100014	-36.000 ppm	30.0 ppm	PASS 21.12 %
0.1 VAC @ 3.99982 kHz	0.0999960	140.45 ppm	0.099986	0.100014	-40.000 ppm	30.0 ppm	PASS 23.47 %
0.1 VAC @ 4.99978 kHz	0.0999960	140.45 ppm	0.099986	0.100014	-40.000 ppm	30.0 ppm	PASS 23.47 %
0.1 VAC @ 6.24972 kHz	0.0999960	140.45 ppm	0.099986	0.100014	-40.000 ppm	30.0 ppm	PASS 23.47 %
0.1 VAC @ 7.99964 kHz	0.0999956	140.45 ppm	0.099986	0.100014	-44.000 ppm	30.0 ppm	PASS 25.81 %
0.1 VAC @ 9.99955 kHz	0.0999957	140.45 ppm	0.099986	0.100014	-43.000 ppm	30.0 ppm	PASS 25.23 %
0.1 VAC @ 14.99932 kHz	0.0999948	140.45 ppm	0.099986	0.100014	-52.000 ppm	30.0 ppm	PASS 30.51 %
0.1 VAC @ 19.9991 kHz	0.0999949	345.45 ppm	0.099965	0.100035	-51.000 ppm	30.0 ppm	PASS 13.58 %
0.1 VAC @ 29.9986 kHz	0.0999941	345.45 ppm	0.099965	0.100035	-59.000 ppm	70.0 ppm	PASS 14.20 %
0.1 VAC @ 49.9977 kHz	0.0999951	886.36 ppm	0.099911	0.100089	-49.000 ppm	70.0 ppm	PASS 5.12 %
0.1 VAC @ 99.9955 kHz	0.1000020	1100.00 ppm	0.099890	0.100110	20.000 ppm	150.0 ppm	PASS 1.60 %
0.1 VAC @ 199.991 kHz	0.0999976	1100.00 ppm	0.099890	0.100110	-24.000 ppm	300.0 ppm	PASS 1.71 %
0.1 VAC @ 299.986 kHz	0.1000051	1700.00 ppm	0.099830	0.100170	51.000 ppm	300.0 ppm	PASS 2.55 %
0.1 VAC @ 499.977 kHz	0.0999995	3500.00 ppm	0.099650	0.100350	-5.000 ppm	300.0 ppm	PASS 0.13 %
0.1 VAC @ 699.968 kHz	0.1000217	3500.00 ppm	0.099650	0.100350	0.0217 %	1000.0 ppm	PASS 4.82 %
0.1 VAC @ 999.955 kHz	0.0999157	140.45 ppm	0.099986	0.100014	-0.0843 %	1000.0 ppm	PASS 73.92 %
0.2 VAC @ 14.99936 Hz	0.1999825	140.45 ppm	0.199972	0.200028	-87.500 ppm	75.0 ppm	PASS 40.61 %
0.2 VAC @ 19.999 Hz	0.1999813	140.45 ppm	0.199972	0.200028	-93.500 ppm	75.0 ppm	PASS 43.40 %
0.2 VAC @ 39.9982 Hz	0.1999816	140.45 ppm	0.199972	0.200028	-92.000 ppm	75.0 ppm	PASS 42.70 %
0.2 VAC @ 49.9977 Hz	0.1999811	140.45 ppm	0.199972	0.200028	-94.500 ppm	30.0 ppm	PASS 55.44 %
0.2 VAC @ 99.9955 Hz	0.1999824	140.45 ppm	0.199972	0.200028	-88.000 ppm	30.0 ppm	PASS 51.63 %
0.2 VAC @ 399.982 Hz	0.1999818	140.45 ppm	0.199972	0.200028	-91.000 ppm	30.0 ppm	PASS 53.39 %
0.2 VAC @ 999.955 Hz	0.1999818	140.45 ppm	0.199972	0.200028	-91.000 ppm	30.0 ppm	PASS 53.39 %
0.2 VAC @ 1.99991 kHz	0.1999824	140.45 ppm	0.199972	0.200028	-88.000 ppm	30.0 ppm	PASS 51.63 %
0.2 VAC @ 2.99986 kHz	0.1999819	140.45 ppm	0.199972	0.200028	-90.500 ppm	30.0 ppm	PASS 53.09 %
0.2 VAC @ 3.99982 kHz	0.1999822	140.45 ppm	0.199972	0.200028	-89.000 ppm	30.0 ppm	PASS 52.21 %
0.2 VAC @ 4.99977 kHz	0.1999818	140.45 ppm	0.199972	0.200028	-91.000 ppm	30.0 ppm	PASS 53.39 %
0.2 VAC @ 6.24972 kHz	0.1999813	140.45 ppm	0.199972	0.200028	-93.500 ppm	30.0 ppm	PASS 54.85 %
0.2 VAC @ 7.99964 kHz	0.1999811	140.45 ppm	0.199972	0.200028	-94.500 ppm	30.0 ppm	PASS 55.44 %
0.2 VAC @ 9.99955 kHz	0.1999803	140.45 ppm	0.199972	0.200028	-98.500 ppm	30.0 ppm	PASS 57.79 %
0.2 VAC @ 14.99932 kHz	0.1999798	345.45 ppm	0.199931	0.200069	-0.0101 %	30.0 ppm	PASS 26.90 %
0.2 VAC @ 19.9991 kHz	0.1999790	345.45 ppm	0.199931	0.200069	-0.0105 %	30.0 ppm	PASS 27.97 %
0.2 VAC @ 29.9986 kHz	0.1999776	886.36 ppm	0.199823	0.200177	-0.0112 %	70.0 ppm	PASS 11.71 %
0.2 VAC @ 49.9977 kHz	0.1999787	1100.00 ppm	0.199780	0.200220	-0.0107 %	70.0 ppm	PASS 9.10 %
0.2 VAC @ 99.9955 kHz	0.1999846	1100.00 ppm	0.199780	0.200220	-77.000 ppm	150.0 ppm	PASS 6.16 %
0.2 VAC @ 199.991 kHz	0.1999793	1700.00 ppm	0.199660	0.200340	-0.0104 %	300.0 ppm	PASS 5.18 %
0.2 VAC @ 299.986 kHz	0.1999895	3500.00 ppm	0.199300	0.200700	-52.500 ppm	300.0 ppm	PASS 1.38 %
0.2 VAC @ 499.977 kHz	0.1999683	3500.00 ppm	0.199300	0.200700	-0.0159 %	300.0 ppm	PASS 4.17 %
0.2 VAC @ 699.968 kHz	0.2000072	73.18 ppm	0.199985	0.200015	36.000 ppm	1000.0 ppm	PASS 3.35 %
0.2 VAC @ 999.955 kHz	0.1998129	73.18 ppm	0.199985	0.200015	-0.0936 %	1000.0 ppm	PASS 87.17 %
0.3 VAC @ 14.9993 Hz	0.3000093	73.18 ppm	0.299978	0.300022	31.000 ppm	75.0 ppm	PASS 20.92 %
0.3 VAC @ 19.9991 Hz	0.3000092	73.18 ppm	0.299978	0.300022	30.667 ppm	75.0 ppm	PASS 20.70 %
0.3 VAC @ 39.9981 Hz	0.3000071	73.18 ppm	0.299978	0.300022	23.667 ppm	75.0 ppm	PASS 15.97 %
0.3 VAC @ 49.9976 Hz	0.3000064	73.18 ppm	0.299978	0.300022	21.333 ppm	30.0 ppm	PASS 20.68 %
0.3 VAC @ 99.9954 Hz	0.3000065	73.18 ppm	0.299978	0.300022	21.667 ppm	30.0 ppm	PASS 21.00 %
0.3 VAC @ 399.982 Hz	0.3000049	73.18 ppm	0.299978	0.300022	16.333 ppm	30.0 ppm	PASS 15.83 %
0.3 VAC @ 999.955 Hz	0.3000053	73.18 ppm	0.299978	0.300022	17.667 ppm	30.0 ppm	PASS 17.12 %
0.3 VAC @ 1.99991 kHz	0.3000056	73.18 ppm	0.299978	0.300022	18.667 ppm	30.0 ppm	PASS 18.09 %
0.3 VAC @ 2.99986 kHz	0.3000063	73.18 ppm	0.299978	0.300022	21.000 ppm	30.0 ppm	PASS 20.35 %
0.3 VAC @ 3.99982 kHz	0.3000058	73.18 ppm	0.299978	0.300022	19.333 ppm	30.0 ppm	PASS 18.74 %

0.3 VAC @ 4.99977 kHz	0.3000055	73.18 ppm	0.299978	0.300022	18.333 ppm	30.0 ppm	PASS 17.77 %
0.3 VAC @ 6.24972 kHz	0.3000058	73.18 ppm	0.299978	0.300022	19.333 ppm	30.0 ppm	PASS 18.74 %
0.3 VAC @ 7.99964 kHz	0.3000042	73.18 ppm	0.299978	0.300022	14.000 ppm	30.0 ppm	PASS 13.57 %
0.3 VAC @ 9.99955 kHz	0.3000054	129.09 ppm	0.299961	0.300039	18.000 ppm	30.0 ppm	PASS 11.31 %
0.3 VAC @ 14.99932 kHz	0.3000052	129.09 ppm	0.299961	0.300039	17.333 ppm	30.0 ppm	PASS 10.90 %
0.3 VAC @ 19.9991 kHz	0.3000053	266.36 ppm	0.299920	0.300080	17.667 ppm	30.0 ppm	PASS 5.96 %
0.3 VAC @ 29.9986 kHz	0.3000082	468.18 ppm	0.299860	0.300140	27.333 ppm	70.0 ppm	PASS 5.08 %
0.3 VAC @ 49.9977 kHz	0.3000142	468.18 ppm	0.299860	0.300140	47.333 ppm	70.0 ppm	PASS 8.80 %
0.3 VAC @ 99.9954 kHz	0.3000407	1200.00 ppm	0.299640	0.300360	0.0136 %	150.0 ppm	PASS 10.05 %
0.3 VAC @ 199.991 kHz	0.3000393	2500.00 ppm	0.299250	0.300750	0.0131 %	300.0 ppm	PASS 4.68 %
0.3 VAC @ 299.986 kHz	0.3001095	2500.00 ppm	0.299250	0.300750	0.0365 %	300.0 ppm	PASS 13.04 %
0.3 VAC @ 499.977 kHz	0.3002378	73.18 ppm	0.299978	0.300022	0.0793 %	300.0 ppm	FAIL 212.41 %
0.3 VAC @ 699.968 kHz	0.3005168	73.18 ppm	0.299978	0.300022	0.1723 %	1000.0 ppm	FAIL 160.52 %
0.3 VAC @ 999.955 kHz	0.3004896	73.18 ppm	0.299978	0.300022	0.1632 %	1000.0 ppm	FAIL 152.07 %
1.0 VAC @ 14.99927 Hz	1.0000067	73.18 ppm	0.999927	1.000073	6.700 ppm	75.0 ppm	PASS 4.52 %
1.0 VAC @ 19.9991 Hz	1.0000047	73.18 ppm	0.999927	1.000073	4.700 ppm	75.0 ppm	PASS 3.17 %
1.0 VAC @ 39.9982 Hz	0.9999986	73.18 ppm	0.999927	1.000073	-1.400 ppm	75.0 ppm	PASS 0.94 %
1.0 VAC @ 49.9978 Hz	0.9999992	73.18 ppm	0.999927	1.000073	-0.800 ppm	30.0 ppm	PASS 0.78 %
1.0 VAC @ 99.9954 Hz	0.9999944	73.18 ppm	0.999927	1.000073	-5.600 ppm	30.0 ppm	PASS 5.43 %
1.0 VAC @ 399.982 Hz	0.9999918	73.18 ppm	0.999927	1.000073	-8.200 ppm	30.0 ppm	PASS 7.95 %
1.0 VAC @ 999.954 Hz	0.9999937	73.18 ppm	0.999927	1.000073	-6.300 ppm	30.0 ppm	PASS 6.11 %
1.0 VAC @ 1.99991 kHz	0.9999969	73.18 ppm	0.999927	1.000073	-3.100 ppm	30.0 ppm	PASS 3.00 %
1.0 VAC @ 2.99986 kHz	0.9999977	73.18 ppm	0.999927	1.000073	-2.300 ppm	30.0 ppm	PASS 2.23 %
1.0 VAC @ 3.99982 kHz	0.9999987	73.18 ppm	0.999927	1.000073	-1.300 ppm	30.0 ppm	PASS 1.26 %
1.0 VAC @ 4.99977 kHz	0.9999968	73.18 ppm	0.999927	1.000073	-3.200 ppm	30.0 ppm	PASS 3.10 %
1.0 VAC @ 6.24972 kHz	0.9999982	73.18 ppm	0.999927	1.000073	-1.800 ppm	30.0 ppm	PASS 1.74 %
1.0 VAC @ 7.99964 kHz	0.9999962	129.09 ppm	0.999871	1.000129	-3.800 ppm	30.0 ppm	PASS 2.39 %
1.0 VAC @ 9.99955 kHz	0.9999987	129.09 ppm	0.999871	1.000129	-1.300 ppm	30.0 ppm	PASS 0.82 %
1.0 VAC @ 14.99932 kHz	0.9999968	266.36 ppm	0.999734	1.000266	-3.200 ppm	30.0 ppm	PASS 1.08 %
1.0 VAC @ 19.9991 kHz	0.9999962	468.18 ppm	0.999532	1.000468	-3.800 ppm	30.0 ppm	PASS 0.76 %
1.0 VAC @ 29.9986 kHz	0.9999979	468.18 ppm	0.999532	1.000468	-2.100 ppm	70.0 ppm	PASS 0.39 %
1.0 VAC @ 49.9977 kHz	1.0000035	1200.00 ppm	0.998800	1.001200	3.500 ppm	70.0 ppm	PASS 0.28 %
1.0 VAC @ 99.9954 kHz	1.0000363	2500.00 ppm	0.997500	1.002500	36.300 ppm	150.0 ppm	PASS 1.37 %
1.0 VAC @ 199.991 kHz	1.0000879	2500.00 ppm	0.997500	1.002500	87.900 ppm	300.0 ppm	PASS 3.14 %
1.0 VAC @ 299.986 kHz	1.0002189	73.18 ppm	0.999927	1.000073	0.0219 %	300.0 ppm	PASS 58.66 %
1.0 VAC @ 499.977 kHz	1.0006754	73.18 ppm	0.999927	1.000073	0.0675 %	300.0 ppm	FAIL 180.99 %
1.0 VAC @ 699.968 kHz	1.0014560	73.18 ppm	0.999927	1.000073	0.1456 %	1000.0 ppm	FAIL 135.67 %
1.0 VAC @ 999.955 kHz	1.0018991	73.18 ppm	0.999927	1.000073	0.1899 %	1000.0 ppm	FAIL 176.96 %
2.0 VAC @ 14.99931 Hz	1.9999240	73.18 ppm	1.999854	2.000146	-38.000 ppm	75.0 ppm	PASS 25.64 %
2.0 VAC @ 19.9991 Hz	1.9999200	73.18 ppm	1.999854	2.000146	-40.000 ppm	75.0 ppm	PASS 26.99 %
2.0 VAC @ 39.9982 Hz	1.9999300	73.18 ppm	1.999854	2.000146	-35.000 ppm	75.0 ppm	PASS 23.62 %
2.0 VAC @ 49.9977 Hz	1.9999120	73.18 ppm	1.999854	2.000146	-44.000 ppm	30.0 ppm	PASS 42.64 %
2.0 VAC @ 99.9955 Hz	1.9999220	73.18 ppm	1.999854	2.000146	-39.000 ppm	30.0 ppm	PASS 37.80 %
2.0 VAC @ 399.982 Hz	1.9999340	73.18 ppm	1.999854	2.000146	-33.000 ppm	30.0 ppm	PASS 31.98 %
2.0 VAC @ 999.954 Hz	1.9999440	73.18 ppm	1.999854	2.000146	-28.000 ppm	30.0 ppm	PASS 27.14 %
2.0 VAC @ 1.99991 kHz	1.9999510	73.18 ppm	1.999854	2.000146	-24.500 ppm	30.0 ppm	PASS 23.74 %
2.0 VAC @ 2.99986 kHz	1.9999560	73.18 ppm	1.999854	2.000146	-22.000 ppm	30.0 ppm	PASS 21.32 %
2.0 VAC @ 3.99982 kHz	1.9999600	73.18 ppm	1.999854	2.000146	-20.000 ppm	30.0 ppm	PASS 19.38 %
2.0 VAC @ 4.99977 kHz	1.9999640	73.18 ppm	1.999854	2.000146	-18.000 ppm	30.0 ppm	PASS 17.45 %
2.0 VAC @ 6.24972 kHz	1.9999650	129.09 ppm	1.999742	2.000258	-17.500 ppm	30.0 ppm	PASS 11.00 %
2.0 VAC @ 7.99963 kHz	1.9999620	129.09 ppm	1.999742	2.000258	-19.000 ppm	30.0 ppm	PASS 11.94 %
2.0 VAC @ 9.99955 kHz	1.9999610	266.36 ppm	1.999467	2.000533	-19.500 ppm	30.0 ppm	PASS 6.58 %
2.0 VAC @ 14.99932 kHz	1.9999630	468.18 ppm	1.999064	2.000936	-18.500 ppm	30.0 ppm	PASS 3.71 %
2.0 VAC @ 19.9991 kHz	1.9999670	468.18 ppm	1.999064	2.000936	-16.500 ppm	30.0 ppm	PASS 3.31 %
2.0 VAC @ 29.9986 kHz	1.9999620	1200.00 ppm	1.997600	2.002400	-19.000 ppm	70.0 ppm	PASS 1.50 %
2.0 VAC @ 49.9977 kHz	1.9999740	2500.00 ppm	1.995000	2.005000	-13.000 ppm	70.0 ppm	PASS 0.51 %
2.0 VAC @ 99.9955 kHz	2.0000300	2500.00 ppm	1.995000	2.005000	15.000 ppm	150.0 ppm	PASS 0.57 %
2.0 VAC @ 199.991 kHz	2.0002240	73.18 ppm	1.999854	2.000146	0.0112 %	300.0 ppm	PASS 30.01 %
2.0 VAC @ 299.986 kHz	2.0005700	73.18 ppm	1.999854	2.000146	0.0285 %	300.0 ppm	PASS 76.37 %
2.0 VAC @ 499.977 kHz	2.0011320	73.18 ppm	1.999854	2.000146	0.0566 %	300.0 ppm	FAIL 151.67 %
2.0 VAC @ 699.968 kHz	2.0024510	73.18 ppm	1.999854	2.000146	0.1226 %	1000.0 ppm	FAIL 114.19 %
2.0 VAC @ 999.955 kHz	2.0016990	73.18 ppm	1.999854	2.000146	0.0849 %	1000.0 ppm	PASS 79.16 %
3.0 VAC @ 14.99927 Hz	2.9999190	73.18 ppm	2.999780	3.000220	-27.000 ppm	75.0 ppm	PASS 18.22 %
3.0 VAC @ 19.9991 Hz	2.9999110	73.18 ppm	2.999780	3.000220	-29.667 ppm	75.0 ppm	PASS 20.02 %
3.0 VAC @ 39.9981 Hz	2.9999170	73.18 ppm	2.999780	3.000220	-27.667 ppm	75.0 ppm	PASS 18.67 %
3.0 VAC @ 49.9977 Hz	2.9999060	73.18 ppm	2.999780	3.000220	-31.333 ppm	30.0 ppm	PASS 30.37 %

3.0 VAC @ 99.9954 Hz	2.9998940	73.18 ppm	2.999780	3.000220	-35.333 ppm	30.0 ppm	PASS 34.24 %
3.0 VAC @ 399.982 Hz	2.9999120	73.18 ppm	2.999780	3.000220	-29.333 ppm	30.0 ppm	PASS 28.43 %
3.0 VAC @ 999.955 Hz	2.9999220	73.18 ppm	2.999780	3.000220	-26.000 ppm	30.0 ppm	PASS 25.20 %
3.0 VAC @ 1.99991 kHz	2.9999320	73.18 ppm	2.999780	3.000220	-22.667 ppm	30.0 ppm	PASS 21.97 %
3.0 VAC @ 2.99986 kHz	2.9999430	73.18 ppm	2.999780	3.000220	-19.000 ppm	30.0 ppm	PASS 18.41 %
3.0 VAC @ 3.99982 kHz	2.9999420	73.18 ppm	2.999780	3.000220	-19.333 ppm	30.0 ppm	PASS 18.74 %
3.0 VAC @ 4.99977 kHz	2.9999410	129.09 ppm	2.999613	3.000387	-19.667 ppm	30.0 ppm	PASS 12.36 %
3.0 VAC @ 6.24972 kHz	2.9999440	129.09 ppm	2.999613	3.000387	-18.667 ppm	30.0 ppm	PASS 11.73 %
3.0 VAC @ 7.99964 kHz	2.9999390	248.18 ppm	2.999255	3.000745	-20.333 ppm	30.0 ppm	PASS 7.31 %
3.0 VAC @ 9.99954 kHz	2.9999390	577.27 ppm	2.998268	3.001732	-20.333 ppm	30.0 ppm	PASS 3.35 %
3.0 VAC @ 14.99932 kHz	2.9999280	577.27 ppm	2.998268	3.001732	-24.000 ppm	30.0 ppm	PASS 3.95 %
3.0 VAC @ 19.9991 kHz	2.9999360	1400.00 ppm	2.995800	3.004200	-21.333 ppm	30.0 ppm	PASS 1.49 %
3.0 VAC @ 29.9986 kHz	2.9999500	3000.00 ppm	2.991000	3.009000	-16.667 ppm	70.0 ppm	PASS 0.54 %
3.0 VAC @ 49.9977 kHz	2.9999860	3000.00 ppm	2.991000	3.009000	-4.667 ppm	70.0 ppm	PASS 0.15 %
3.0 VAC @ 99.9954 kHz	3.0002130	73.18 ppm	2.999780	3.000220	71.000 ppm	150.0 ppm	PASS 31.81 %
3.0 VAC @ 199.991 kHz	3.0001990	73.18 ppm	2.999780	3.000220	66.333 ppm	300.0 ppm	PASS 17.78 %
3.0 VAC @ 299.986 kHz	3.0005840	73.18 ppm	2.999780	3.000220	0.0195 %	300.0 ppm	PASS 52.16 %
3.0 VAC @ 499.977 kHz	3.0012230	73.18 ppm	2.999780	3.000220	0.0408 %	300.0 ppm	FAIL 109.24 %
3.0 VAC @ 699.968 kHz	3.0029220	73.18 ppm	2.999780	3.000220	0.0974 %	1000.0 ppm	PASS 90.76 %
3.0 VAC @ 999.955 kHz	3.0022880	73.18 ppm	2.999780	3.000220	0.0763 %	1000.0 ppm	PASS 71.07 %
10.0 VAC @ 14.9993 Hz	9.9997240	73.18 ppm	9.999268	10.000732	-27.600 ppm	75.0 ppm	PASS 18.63 %
10.0 VAC @ 19.9991 Hz	9.9996640	73.18 ppm	9.999268	10.000732	-33.600 ppm	75.0 ppm	PASS 22.68 %
10.0 VAC @ 39.9982 Hz	9.9996080	73.18 ppm	9.999268	10.000732	-39.200 ppm	75.0 ppm	PASS 26.45 %
10.0 VAC @ 49.9978 Hz	9.9996070	73.18 ppm	9.999268	10.000732	-39.300 ppm	30.0 ppm	PASS 38.09 %
10.0 VAC @ 99.9954 Hz	9.9995870	73.18 ppm	9.999268	10.000732	-41.300 ppm	30.0 ppm	PASS 40.03 %
10.0 VAC @ 399.982 Hz	9.9996230	73.18 ppm	9.999268	10.000732	-37.700 ppm	30.0 ppm	PASS 36.54 %
10.0 VAC @ 999.955 Hz	9.9996690	73.18 ppm	9.999268	10.000732	-33.100 ppm	30.0 ppm	PASS 32.08 %
10.0 VAC @ 1.99991 kHz	9.9996960	73.18 ppm	9.999268	10.000732	-30.400 ppm	30.0 ppm	PASS 29.46 %
10.0 VAC @ 2.99986 kHz	9.9997230	73.18 ppm	9.999268	10.000732	-27.700 ppm	30.0 ppm	PASS 26.85 %
10.0 VAC @ 3.99982 kHz	9.9997470	129.09 ppm	9.998709	10.001291	-25.300 ppm	30.0 ppm	PASS 15.90 %
10.0 VAC @ 4.99977 kHz	9.9997380	129.09 ppm	9.998709	10.001291	-26.200 ppm	30.0 ppm	PASS 16.47 %
10.0 VAC @ 6.24971 kHz	9.9997670	248.18 ppm	9.997518	10.002482	-23.300 ppm	30.0 ppm	PASS 8.38 %
10.0 VAC @ 7.99964 kHz	9.9997560	577.27 ppm	9.994227	10.005773	-24.400 ppm	30.0 ppm	PASS 4.02 %
10.0 VAC @ 9.99955 kHz	9.9997560	577.27 ppm	9.994227	10.005773	-24.400 ppm	30.0 ppm	PASS 4.02 %
10.0 VAC @ 14.99932 kHz	9.9997610	1400.00 ppm	9.986000	10.014000	-23.900 ppm	30.0 ppm	PASS 1.67 %
10.0 VAC @ 19.9991 kHz	9.9997750	3000.00 ppm	9.970000	10.030000	-22.500 ppm	30.0 ppm	PASS 0.74 %
10.0 VAC @ 29.9986 kHz	9.9997800	3000.00 ppm	9.970000	10.030000	-22.000 ppm	70.0 ppm	PASS 0.72 %
10.0 VAC @ 49.9977 kHz	9.9997850	73.18 ppm	9.999268	10.000732	-21.500 ppm	70.0 ppm	PASS 15.02 %
10.0 VAC @ 99.9955 kHz	9.9999750	73.18 ppm	9.999268	10.000732	-2.500 ppm	150.0 ppm	PASS 1.12 %
10.0 VAC @ 199.991 kHz	10.0007310	73.18 ppm	9.999268	10.000732	73.100 ppm	300.0 ppm	PASS 19.59 %
10.0 VAC @ 299.986 kHz	10.0021170	73.18 ppm	9.999268	10.000732	0.0212 %	300.0 ppm	PASS 56.73 %
10.0 VAC @ 499.977 kHz	10.0066590	73.18 ppm	9.999268	10.000732	0.0666 %	300.0 ppm	FAIL 178.44 %
10.0 VAC @ 699.968 kHz	10.0165000	73.18 ppm	9.999268	10.000732	0.1650 %	1000.0 ppm	FAIL 153.75 %
10.0 VAC @ 999.955 kHz	10.0241270	73.18 ppm	9.999268	10.000732	0.2413 %	1000.0 ppm	FAIL 224.82 %
20.0 VAC @ 14.9994 Hz	19.9991800	73.18 ppm	19.998536	20.001464	-41.000 ppm	75.0 ppm	PASS 27.67 %
20.0 VAC @ 19.9991 Hz	19.9990800	73.18 ppm	19.998536	20.001464	-46.000 ppm	75.0 ppm	PASS 31.04 %
20.0 VAC @ 39.9982 Hz	19.9990000	73.18 ppm	19.998536	20.001464	-50.000 ppm	75.0 ppm	PASS 33.74 %
20.0 VAC @ 49.9977 Hz	19.9990300	73.18 ppm	19.998536	20.001464	-48.500 ppm	30.0 ppm	PASS 47.01 %
20.0 VAC @ 99.9954 Hz	19.9990600	73.18 ppm	19.998536	20.001464	-47.000 ppm	30.0 ppm	PASS 45.55 %
20.0 VAC @ 399.982 Hz	19.9992100	73.18 ppm	19.998536	20.001464	-39.500 ppm	30.0 ppm	PASS 38.28 %
20.0 VAC @ 999.955 Hz	19.9992900	73.18 ppm	19.998536	20.001464	-35.500 ppm	30.0 ppm	PASS 34.41 %
20.0 VAC @ 1.99991 kHz	19.9993800	73.18 ppm	19.998536	20.001464	-31.000 ppm	30.0 ppm	PASS 30.04 %
20.0 VAC @ 2.99986 kHz	19.9994300	129.09 ppm	19.997418	20.002582	-28.500 ppm	30.0 ppm	PASS 17.91 %
20.0 VAC @ 3.99982 kHz	19.9994800	129.09 ppm	19.997418	20.002582	-26.000 ppm	30.0 ppm	PASS 16.34 %
20.0 VAC @ 4.99977 kHz	19.9994800	248.18 ppm	19.995036	20.004964	-26.000 ppm	30.0 ppm	PASS 9.35 %
20.0 VAC @ 6.24972 kHz	19.9994800	577.27 ppm	19.988455	20.011545	-26.000 ppm	30.0 ppm	PASS 4.28 %
20.0 VAC @ 7.99964 kHz	19.9994900	577.27 ppm	19.988455	20.011545	-25.500 ppm	30.0 ppm	PASS 4.20 %
20.0 VAC @ 9.99955 kHz	19.9994800	1400.00 ppm	19.972000	20.028000	-26.000 ppm	30.0 ppm	PASS 1.82 %
20.0 VAC @ 14.99932 kHz	19.9994600	3000.00 ppm	19.940000	20.060000	-27.000 ppm	30.0 ppm	PASS 0.89 %
20.0 VAC @ 19.9991 kHz	19.9994600	3000.00 ppm	19.940000	20.060000	-27.000 ppm	30.0 ppm	PASS 0.89 %
20.0 VAC @ 29.9986 kHz	19.9994600	73.18 ppm	19.998536	20.001464	-27.000 ppm	70.0 ppm	PASS 18.86 %
20.0 VAC @ 49.9977 kHz	19.9992500	73.18 ppm	19.998536	20.001464	-37.500 ppm	70.0 ppm	PASS 26.19 %
20.0 VAC @ 99.9955 kHz	19.9988900	73.18 ppm	19.998536	20.001464	-55.500 ppm	150.0 ppm	PASS 24.87 %
20.0 VAC @ 199.991 kHz	19.9983700	73.18 ppm	19.998536	20.001464	-81.500 ppm	300.0 ppm	PASS 21.84 %
20.0 VAC @ 299.986 kHz	19.9918700	73.18 ppm	19.998536	20.001464	-0.0407 %	300.0 ppm	FAIL 108.93 %
20.0 VAC @ 499.977 kHz	19.9498500	73.18 ppm	19.998536	20.001464	-0.2507 %	300.0 ppm	FAIL 671.93 %

20.0 VAC @ 699.968 kHz	19.9462100	73.18 ppm	19.998536	20.001464	-0.2690 %	1000.0 ppm	FAIL 250.61 %
20.0 VAC @ 999.955 kHz	20.0138100	73.18 ppm	19.998536	20.001464	0.0690 %	1000.0 ppm	PASS 64.34 %
30.0 VAC @ 14.99926 Hz	29.9989600	73.18 ppm	29.997805	30.002195	-34.667 ppm	75.0 ppm	PASS 23.39 %
30.0 VAC @ 19.9991 Hz	29.9989400	73.18 ppm	29.997805	30.002195	-35.333 ppm	75.0 ppm	PASS 23.84 %
30.0 VAC @ 39.9981 Hz	29.9988500	73.18 ppm	29.997805	30.002195	-38.333 ppm	75.0 ppm	PASS 25.87 %
30.0 VAC @ 49.9977 Hz	29.9987200	73.18 ppm	29.997805	30.002195	-42.667 ppm	30.0 ppm	PASS 41.35 %
30.0 VAC @ 99.9955 Hz	29.9987700	73.18 ppm	29.997805	30.002195	-41.000 ppm	30.0 ppm	PASS 39.74 %
30.0 VAC @ 399.982 Hz	29.9987800	73.18 ppm	29.997805	30.002195	-40.667 ppm	30.0 ppm	PASS 39.41 %
30.0 VAC @ 999.955 Hz	29.9989300	73.18 ppm	29.997805	30.002195	-35.667 ppm	30.0 ppm	PASS 34.57 %
30.0 VAC @ 1.99991 kHz	29.9991500	129.09 ppm	29.996127	30.003873	-28.333 ppm	30.0 ppm	PASS 17.81 %
30.0 VAC @ 2.99986 kHz	29.9993600	129.09 ppm	29.996127	30.003873	-21.333 ppm	30.0 ppm	PASS 13.41 %
30.0 VAC @ 3.99982 kHz	29.9994000	248.18 ppm	29.992555	30.007445	-20.000 ppm	30.0 ppm	PASS 7.19 %
30.0 VAC @ 4.99977 kHz	29.9994800	577.27 ppm	29.982682	30.017318	-17.333 ppm	30.0 ppm	PASS 2.85 %
30.0 VAC @ 6.24972 kHz	29.9993400	577.27 ppm	29.982682	30.017318	-22.000 ppm	30.0 ppm	PASS 3.62 %
30.0 VAC @ 7.99964 kHz	29.9992900	1400.00 ppm	29.958000	30.042000	-23.667 ppm	30.0 ppm	PASS 1.66 %
30.0 VAC @ 9.99955 kHz	29.9992200	3000.00 ppm	29.910000	30.090000	-26.000 ppm	30.0 ppm	PASS 0.86 %
30.0 VAC @ 14.99932 kHz	29.9992400	3000.00 ppm	29.910000	30.090000	-25.333 ppm	30.0 ppm	PASS 0.84 %
30.0 VAC @ 19.9991 kHz	29.9992300	73.18 ppm	29.997805	30.002195	-25.667 ppm	30.0 ppm	PASS 24.88 %
30.0 VAC @ 29.9986 kHz	29.9990500	73.18 ppm	29.997805	30.002195	-31.667 ppm	70.0 ppm	PASS 22.12 %
30.0 VAC @ 49.9977 kHz	29.9990300	73.18 ppm	29.997805	30.002195	-32.333 ppm	70.0 ppm	PASS 22.58 %
30.0 VAC @ 99.9955 kHz	29.9972400	73.18 ppm	29.997805	30.002195	-92.000 ppm	150.0 ppm	PASS 41.22 %
30.0 VAC @ 199.991 kHz	29.9969700	73.18 ppm	29.997805	30.002195	-0.0101 %	300.0 ppm	PASS 27.06 %
30.0 VAC @ 299.986 kHz	29.9814400	73.18 ppm	29.997805	30.002195	-0.0619 %	300.0 ppm	FAIL 165.78 %
30.0 VAC @ 499.977 kHz	29.8891800	73.18 ppm	29.997805	30.002195	-0.3694 %	300.0 ppm	FAIL 989.87 %
30.0 VAC @ 699.968 kHz	29.8241700	73.18 ppm	29.997805	30.002195	-0.5861 %	1000.0 ppm	FAIL 546.13 %
100.0 VAC @ 14.99931 Hz	99.9964100	73.18 ppm	99.992682	100.007318	-35.900 ppm	75.0 ppm	PASS 24.23 %
100.0 VAC @ 19.9991 Hz	99.9955800	73.18 ppm	99.992682	100.007318	-44.200 ppm	75.0 ppm	PASS 29.83 %
100.0 VAC @ 39.9982 Hz	99.9954100	73.18 ppm	99.992682	100.007318	-45.900 ppm	75.0 ppm	PASS 30.98 %
100.0 VAC @ 49.9977 Hz	99.9954500	73.18 ppm	99.992682	100.007318	-45.500 ppm	30.0 ppm	PASS 44.10 %
100.0 VAC @ 99.9954 Hz	99.9953900	73.18 ppm	99.992682	100.007318	-46.100 ppm	30.0 ppm	PASS 44.68 %
100.0 VAC @ 399.982 Hz	99.9952600	73.18 ppm	99.992682	100.007318	-47.400 ppm	30.0 ppm	PASS 45.94 %
100.0 VAC @ 999.955 Hz	99.9957300	73.18 ppm	99.992682	100.007318	-42.700 ppm	30.0 ppm	PASS 41.38 %
100.0 VAC @ 1.99991 kHz	99.9964400	129.09 ppm	99.987091	100.012909	-35.600 ppm	30.0 ppm	PASS 22.38 %
100.0 VAC @ 2.99986 kHz	99.9968200	129.09 ppm	99.987091	100.012909	-31.800 ppm	30.0 ppm	PASS 19.99 %
100.0 VAC @ 3.99982 kHz	99.9971400	248.18 ppm	99.975182	100.024818	-28.600 ppm	30.0 ppm	PASS 10.28 %
100.0 VAC @ 4.99977 kHz	99.9973700	577.27 ppm	99.942273	100.057727	-26.300 ppm	30.0 ppm	PASS 4.33 %
100.0 VAC @ 6.24972 kHz	99.9971400	577.27 ppm	99.942273	100.057727	-28.600 ppm	30.0 ppm	PASS 4.71 %
100.0 VAC @ 7.99964 kHz	99.9972800	1400.00 ppm	99.860000	100.140000	-27.200 ppm	30.0 ppm	PASS 1.90 %
100.0 VAC @ 9.99955 kHz	99.9971100	3000.00 ppm	99.700000	100.300000	-28.900 ppm	30.0 ppm	PASS 0.95 %
100.0 VAC @ 14.99932 kHz	99.9970100	3000.00 ppm	99.700000	100.300000	-29.900 ppm	30.0 ppm	PASS 0.99 %
100.0 VAC @ 19.9991 kHz	99.9969300	73.18 ppm	99.992682	100.007318	-30.700 ppm	30.0 ppm	PASS 29.75 %
100.0 VAC @ 29.9986 kHz	99.9963000	73.18 ppm	99.992682	100.007318	-37.000 ppm	70.0 ppm	PASS 25.84 %
100.0 VAC @ 49.9977 kHz	99.9954300	73.18 ppm	99.992682	100.007318	-45.700 ppm	70.0 ppm	PASS 31.92 %
100.0 VAC @ 99.9955 kHz	99.9860700	73.18 ppm	99.992682	100.007318	-0.0139 %	150.0 ppm	PASS 62.42 %
100.0 VAC @ 199.991 kHz	99.9672900	73.18 ppm	99.992682	100.007318	-0.0327 %	300.0 ppm	PASS 87.65 %
200.0 VAC @ 14.9993 Hz	199.9984000	73.18 ppm	199.985364	200.014636	-8.000 ppm	80.0 ppm	PASS 5.22 %
200.0 VAC @ 19.9991 Hz	199.9979000	73.18 ppm	199.985364	200.014636	-10.500 ppm	80.0 ppm	PASS 6.85 %
200.0 VAC @ 39.9981 Hz	199.9971000	73.18 ppm	199.985364	200.014636	-14.500 ppm	80.0 ppm	PASS 9.47 %
200.0 VAC @ 49.9977 Hz	199.9967000	73.18 ppm	199.985364	200.014636	-16.500 ppm	35.0 ppm	PASS 15.25 %
200.0 VAC @ 99.9954 Hz	199.9968000	73.18 ppm	199.985364	200.014636	-16.000 ppm	35.0 ppm	PASS 14.79 %
200.0 VAC @ 399.982 Hz	199.9969000	73.18 ppm	199.985364	200.014636	-15.500 ppm	35.0 ppm	PASS 14.33 %
200.0 VAC @ 999.954 Hz	199.9976000	73.18 ppm	199.985364	200.014636	-12.000 ppm	35.0 ppm	PASS 11.09 %
200.0 VAC @ 1.99991 kHz	199.9982000	73.18 ppm	199.985364	200.014636	-9.000 ppm	35.0 ppm	PASS 8.32 %
200.0 VAC @ 2.99986 kHz	199.9987000	73.18 ppm	199.985364	200.014636	-6.500 ppm	35.0 ppm	PASS 6.01 %
200.0 VAC @ 3.99982 kHz	199.9993000	73.18 ppm	199.985364	200.014636	-3.500 ppm	35.0 ppm	PASS 3.24 %
200.0 VAC @ 4.99977 kHz	199.9995000	129.09 ppm	199.974182	200.025818	-2.500 ppm	35.0 ppm	PASS 1.52 %
200.0 VAC @ 6.24971 kHz	199.9996000	129.09 ppm	199.974182	200.025818	-2.000 ppm	35.0 ppm	PASS 1.22 %
200.0 VAC @ 7.99963 kHz	199.9995000	248.18 ppm	199.950364	200.049636	-2.500 ppm	35.0 ppm	PASS 0.88 %
200.0 VAC @ 9.99954 kHz	200.0001000	577.27 ppm	199.884546	200.115454	0.500 ppm	35.0 ppm	PASS 0.08 %
200.0 VAC @ 14.99931 kHz	200.0053000	577.27 ppm	199.884546	200.115454	26.500 ppm	35.0 ppm	PASS 4.33 %
200.0 VAC @ 19.9991 kHz	200.0149000	1400.00 ppm	199.720000	200.280000	74.500 ppm	35.0 ppm	PASS 5.19 %
200.0 VAC @ 29.9986 kHz	200.0525000	3000.00 ppm	199.400000	200.600000	0.0263 %	75.0 ppm	PASS 8.54 %
200.0 VAC @ 49.9977 kHz	200.0511000	3000.00 ppm	199.400000	200.600000	0.0255 %	75.0 ppm	PASS 8.31 %
200.0 VAC @ 99.9954 kHz	199.9782000	73.18 ppm	199.985364	200.014636	-0.0109 %	150.0 ppm	PASS 48.84 %
300.0 VAC @ 49.9977 Hz	300.0063000	73.18 ppm	299.978046	300.021954	21.000 ppm	35.0 ppm	PASS 19.41 %
300.0 VAC @ 99.9954 Hz	300.0026000	73.18 ppm	299.978046	300.021954	8.667 ppm	35.0 ppm	PASS 8.01 %

300.0 VAC @ 399.982 Hz	300.0032000	73.18 ppm	299.978046	300.021954	10.667 ppm	35.0 ppm	PASS 9.86 %
300.0 VAC @ 999.954 Hz	300.0028000	73.18 ppm	299.978046	300.021954	9.333 ppm	35.0 ppm	PASS 8.63 %
300.0 VAC @ 1.99991 kHz	300.0058000	73.18 ppm	299.978046	300.021954	19.333 ppm	35.0 ppm	PASS 17.87 %
300.0 VAC @ 2.99986 kHz	300.0071000	73.18 ppm	299.978046	300.021954	23.667 ppm	35.0 ppm	PASS 21.88 %
300.0 VAC @ 3.99982 kHz	300.0082000	73.18 ppm	299.978046	300.021954	27.333 ppm	35.0 ppm	PASS 25.27 %
300.0 VAC @ 4.99977 kHz	300.0083000	73.18 ppm	299.978046	300.021954	27.667 ppm	35.0 ppm	PASS 25.57 %
300.0 VAC @ 6.24971 kHz	300.0096000	73.18 ppm	299.978046	300.021954	32.000 ppm	35.0 ppm	PASS 29.58 %
300.0 VAC @ 7.99963 kHz	300.0122000	73.18 ppm	299.978046	300.021954	40.667 ppm	35.0 ppm	PASS 37.59 %
300.0 VAC @ 9.99954 kHz	300.0147000	73.18 ppm	299.978046	300.021954	49.000 ppm	35.0 ppm	PASS 45.29 %
300.0 VAC @ 14.99931 kHz	300.0225000	73.18 ppm	299.978046	300.021954	75.000 ppm	35.0 ppm	PASS 69.33 %
300.0 VAC @ 19.9991 kHz	300.0381000	73.18 ppm	299.978046	300.021954	0.0127 %	35.0 ppm	FAIL 117.40 %
300.0 VAC @ 29.9986 kHz	300.1017000	73.18 ppm	299.978046	300.021954	0.0339 %	75.0 ppm	FAIL 228.78 %
300.0 VAC @ 49.9977 kHz	300.1143000	129.09 ppm	299.961273	300.038727	0.0381 %	75.0 ppm	FAIL 186.68 %
500 VAC @ 49.9977 Hz	499.9916000	129.09 ppm	499.935455	500.064545	-16.800 ppm	35.0 ppm	PASS 10.24 %
500 VAC @ 99.9954 Hz	499.9921000	248.18 ppm	499.875910	500.124090	-15.800 ppm	35.0 ppm	PASS 5.58 %
500 VAC @ 399.982 Hz	499.9920000	577.27 ppm	499.711365	500.288635	-16.000 ppm	35.0 ppm	PASS 2.61 %
500 VAC @ 999.954 Hz	499.9936000	577.27 ppm	499.711365	500.288635	-12.800 ppm	35.0 ppm	PASS 2.09 %

Test completed

Test date	02 October 2021 13:39
UUT Internal TEMP?	NONE

Lab temperature maintained +23°C ±2°C

Internal use only

Not validated

Cal.equipment

Test block

2021 © cal.equipment